

SECTION 6

6.12 VALVE BOXES:

All buried gate valves 12 inches and smaller shall be provided with a 6 inch cast iron valve box, Buffalo type, and large oval base. The valve box shall be of a design, which will not transmit shock or stress to the valve and shall have enough extension capability to be raised to final street grade. Valve boxes shall conform to MS-11. The valve box shall be allowable for use with a butterfly valve as shown on Sheet 18 of the Standard Drawings.